
Concure Systems ADMIXTURE

PART 1 GENERAL

1.01 SUBMITTALS

A. Closeout Submittals: Submit the following:

1. Warranty: Warranty documents specified herein.

1.02 DELIVERY, STORAGE & HANDLING

A. Store materials protected from exposure to harmful weather conditions and at a temperature above 45° Fahrenheit.

1.03 WARRANTY

A. Project Warranty: Refer to Conditions of the Contract for Project warranty provisions.

B. Manufacturer's Warranty: Submit, for the owner's acceptance, the manufacturer's standard warranty document executed by an authorized company official. The manufacturer's warranty is in addition to, and not a limitation of, other rights the Owner may have under provisions of the contract documents.

1. Warranty Period: Ten years commencing on the date of acceptance of the project by the Owner or Notice of Completion which ever is earliest.
2. Warranty Terms: Terms to include moisture related failures, including all finish floor materials and labor.

PART 2 PRODUCTS

2.01 CONCRETE WATERPROOFING ADMIXTURE

A. Manufacturer: Concure Systems 1618 E. Briarwood Terrace, Phoenix, AZ 85048 Telephone (480) 820-7171 Fax (480) 820-7787 e-mail epikula@cox.net

B. Admixture: Concure Systems Admixture

C. Accessory Materials.

1. Concure Systems Crack Fill Binder.

2.02 MIXING

A. Add 14 ounces of Concure admixture per 100 lbs. of cementitious material to ready mix truck at the batch plant, or jobsite before discharge, mix rapidly for 7 minutes. (Follow Manufacturer's Instructions).

B. To be used in lieu of, designed, mix water. Not in addition to mix water. Do not alter water/cement ratio. W/c .45 or less and a maximum slump of 4 inches.

C. The addition of non-chlorinated admixtures is permitted. (Follow Manufacturer's Instructions).

2.03 TESTING

A. Concure tests by either ASTM D5084 or ASTM 4263 only and Calcium Chloride testing is not required or recognized due to inaccuracy of results.

2.04 PRODUCT SUBSTITUTIONS

Substitutions allowed meeting the following criteria:

- A. Full warranty on above based terms W/O use of under slab VAPOR BARRIER

- B. Product must have MINIMUM 10 years no fail experience in the flooring/Concrete industry.